Jer OCTOPUS

Anaerobic Baffled Reactor - maturation ponds



05 December 2019

Organisation that implemented the case study

Save the Children International

Geographic location

Rakhine Pauktaw Township - Sin Tet Maw IDP camp, Myanmar (Burma)

Main treatment objectives

BOD / COD Reduction Pathogen reduction Solid/liquid separation TSS and TDS reduction

Technologies employed

Anaerobic baffled reactor Anaerobic filter Co-composting Infiltration

Sedimentation tank Settling-thickening tank Unplanted drying beds

Design population

2523 persons

Source of sludge

Health facilities Public toilets Septic tank connected by greywater

> Final outputs Compost Effluent

Time construction and commissioning

TS Reduction 3.50 %

Opex per real input flow 4.20 USD/m³

Required space 0.68 m²/m³ of design input flow

Design input flow

5.00 m²/day

Skills level

Communitarian operation FSM specialist for construction FSM specialist for design FSM specialist for operation and maintenance

> COD Reduction 85.90 %

Resources needed for operation Engine

> Real input flow 2.50 m³/day

Description of the emergency context



Pauktaw is a zone that was directly affected by the October 2012 ethnic conflict. IDPs, Host Communities and isolated villages are facing an immediate need for water, sanitation and hygiene education as well as access to health and nutrition services. This is especially important given the crowded conditions in most of these neighborhoods.

Sin Thet Maw camp, in Pauktaw is supported for the WASH activities by Save the Children. In term of sanitation, around 430 latrines have been built for this camp hosting 682 households and 2523 beneficiaries. The waterproof aspect of the latrine pits implies a filling of the latrines pits. Once the pit full, create another pit and latrine is not possible for a reason of land availability. Like for the Sittwe camps, desludging of the latrines and treatment of the sludge have been considered.

Community

- Dimensions or area: 800,000 square feet (7.5 hectares)

- Livelihood: mainly fishery

- Type of shelter/house: long house shelter

- HHs dimensions: average of 3.7 individuals per household

- Living area of community: Sin Thet Maw IDP camp, 20° 4'4.33"N, 92°59'33.56"E, 35min boat trip from Sittwe Golden River Jetty)

- Population increase/decrease forecast: 6-10% annual growth

- Type of site: semi-permanent camp

- Type of context: rural

- Other WaSH activities implemented in the community: hygiene promotion, water treatment and distribution, drainage, solid waste management.

- Local and international WaSH institutions with WaSH active role in the community and specific partnerships: only Save The Children is the WASH service provider

- Main waterborne diseases: AWD



- A first physical treatment by filtering through a grid the object present,

- A second physical treatment in a sludge drying bed: a settlement tank to separate the sludge into a solid part and a liquid part, which is clearly the first module in terms of construction.

- A third physical treatment: a settler to polish the sedimentation,

- A first biological treatment: an Anaerobic Baffled Reactor (ABR) to degrade the suspended and dissolved solids,

- A second biological treatment: two aerobic maturation pond to remove pathogens, on which is added a polishing pond.

Assessment & design (feasibility)



During the monsoon 2014, temporary piezometer have been set to ensure the highest groundwater level into the compound. The groundwater level measurement is 2.5 feet from the surface.

- Inlet sludge parameters measured and their mean value: CODin = 35,000 mg/l ; BODin = 8,000 mg/l.

- Mean number of users per pit: 14.4 user per pit

- Flush or dry toilet: dry

- Type of material for anal cleansing: water

- Presence of solid waste in the pits: yes

- Desludging and transportation system: motorized desludging

- Desludging organizations: formal, well equipped, covering the needs

Local safety requirements:

- integrated overall (covering the hair)
- Rubber gloves,
- Boots,
- Masks,
- Bathing space

Other information:

- Production of sludge per person per day considered for the design: 1.92L

- Design time life of the plant: years

- Design formulas used: See design in annex – BORDA formulas were used.

- Reference documents used for the design of the plant: Decentralised Wastewater Treatment Systems (DEWATS) and Sanitation in Developing Countries

- Special skills necessary for the design: Civil engineering / hydrogeology / biology / fluid mechanics

- Mitigation of the local constraints: high water table, flood prone area, earthquakes.

- Type of climate: tropical monsoon climate

Construction



Construction material of the different treatment modules:

- Cement
- Sand
- Gravel
- Bricks
- Iron bars
- PVC pipes & fittings
- GI pipes & fittings
- Clay (bricks)
- Zinc sheetings
- Wooden beams / timber

Other information:

- Construction and installation methodology: camp based contractor

- Time needed for construction and installation: 7 months

- Area of the total land used and area of the treatment modules: 1,725m2

- Special skills necessary for the construction of the plant: Masons, carpenters, civil engineer, hydrogeologist, environmental health specialist

- Number of workers needed to operate and their skill level: 6 workers operate and maintain the plant on a regular basis.

- Spare parts needed and availability locally/internationally: STS require fuel (for the pumps), water testing consumables and minor maintenance budgeted for a cost of \$ 200 monthly.

- Social acceptance: Good because STS is settle at a reasonable distance of the households' shelters

- Washing facilities available: Bathing space

- Access to the plant: Walking or tractor
- Site protected by a fence: Yes

Lessons learned

Were you able to reduce the inlet quantity of sludge of the plant? How? Not needed Were the design hypotheses correct? Yes Have the design rules given the expected results? Yes How have you reduced contact between staff and sludge? Safety equipment What good practices would you recommend? A design with sufficient treatment capacity Construction period not during water scarcity period and neither during monsoon.

Strengths

- Well designed

- Good location

Weaknesses

- Challenging to ensure a proper handover to the Government for the operation and maintenance of the facility after camp closure.

- Not an income generating activity.

Image Gallery



Add new comment